



# DAM INSPECTION CHECKLIST POSSUM POINT POWER STATION POND ABC

INSPECTION DATE: 09/28/2015

WEATHER: Clear skies, 80's, humid

INSPECTED BY: Brian Hall

Location/ Condition	(y/n)	Change (y/n)	Comments
Low Point, A dike*			
Flow	N	N	0733 hours. No changes
Erosion	N	N	from previous inspection
Low Point, B dike*			
Flow	N	N	0736 hours. No changes
Erosion	N	N	From previous inspection
Outfall water surface El. (top of stoplogs to water)			0735 hours No water flowing into weir. Discharge pipe sealed. Pumps are running

\* See figure below.

**Additional Comments (Note any changes observed along the embankment crest or downstream slope observed from the crest.):** No standing water where there had been some at the base of the slope between A and B.

